

PART 1 **GENERAL**

The following changes are effective immediately and shall be incorporated into the Contract Documents.

PART 2 **INFORMATION/CLARIFICATION [NOT USED]**

PART 3 **SPECIFICATIONS**

3.1 **AMEND SECTION CONTROL DEVICES 26 29 03**

.1 **Add Section 2.16 INFRARED HEATERS**

- .1** Process heating infrared heaters
- .2** Electrical Supply: 600V/1/60HZ
- .3** Standard of Acceptance: Caloritech OKA – Type R 60° Spread 3.6kW complete with wire guard. Units wired in delta.

PART 4 **QUESTIONS AND ANSWERS [NOT USED]**

4.1

END OF ADDENDUM #2