



ADDENDUM No. 1

Date Issued: February 3, 2025

To: All Bidders

Subject: Amendment to RFT ISD24-134 Request for Tender (RFT) for Wanapitei Water Treatment Plant Filter Upgrades

The following information, amendments, and revisions shall form an integral part of the Bid Solicitation Documents and where applicable, shall supersede requirements of other Bid Solicitation Documents. Refer to Section 5.1.3 of the Bid Solicitation.

QUESTIONS & ANSWERS:

Question 1:

Can you confirm if the filter media being removed is classified as contaminated waste since it has chemicals in it from the treatment process.

Answer 1:

The filter media being removed is not classified as contaminated waste.

****End of Addendum****